Safe Drinking Water Act 2003 Monitoring Requirements

LEISURE ARMS COMPLEX
PWSID#: 1704001

Part 1: **Distribution System Monitoring Requirements**

Population served: 60

Date Issued: 01/28/03

Coliform	Lead/Copper Water Quality	Iron and Manganese	Total Trihalomethanes	Asbestos	Radionuclides
2 sample(s) per month	Grand Reduction-5 samples between June-Sept 2004-2006	Not Required	Not Required	If needed will be notified by the BSDW	One sample between 7/01/00 and 6/30/04
Disenfectant Residual Not required			HAA5 Not required		

Notes:

For Surface Water Systems turbidity measurements shall be taken every 4hrs from the continuous recorder or grab samples at the filtration plant. The # of samples required for Chlorine residual measurements, to be taken in the distribution system, are equal to the # of Coliform samples required. Reporting required monthly.

Safe Drinking Water Act 2003 Monitoring Requirements

LEISURE ARMS COMPLEX

PWSID#: 1704001

Date Issued: 01/28/03

Part 2: Point of Entry Monitoring Requirements

Point of Entry #: 01 Name: WELL 1 & 2 TP

Availability: Permanent Source

Nitrate	Volatile Organic Compounds	Inorganic Contaminants	Secondary Contaminants	Water Quality Parameters	Asbestos	Synthetic Organic Comp.	DBP Precursor
Once in 2003	Once in 2003 R&C	Once in 2003	Once in 2003	Not required	Not required	State waiver-not required	

Notes:
1. All emergency sources must be sampled if and when used
2. If a point of entry is taken off line for an extended period of time you must notify this Bureau